



State Water Resources Control Board

Division of Drinking Water

Lead and Copper Tap Sample Results Reporting Form

This form must be submitted by the public water system to the regulating entity (DDW District Office or County Agency) for each round of lead and copper sampling

Report Date: (mm/dd/yyyy)	10/27/2020
Water System Name:	Groveland CSD
Water System Number:	5510009
Water System Type:	<input checked="" type="radio"/> Community <input type="radio"/> Non-Transient, Non Community
Monitoring Frequency:	<input type="radio"/> 6-month <input type="radio"/> Annual <input checked="" type="radio"/> Triennial
# of Samples Required:	20
# of Samples Reported:	20
	90th Percentile Level (mg/L)
Lead: <i>Action Level = 0.015 mg/L</i>	ND
Copper: <i>Action Level = 1.3 mg/L</i>	0.047

	Sample Date	Sample Site Location/Address	Tier 1, 2, 3, or R	Result	
				Lead (mg/L)	Copper (mg/L)
01	8/12/2020	17791 HWY 120	1	ND	.0762
02	8/12/2020	18653 MAIN ST	1	ND	.00247
03	8/12/2020	18936 FLINT CT	1	ND	.00407
04	8/12/2020	19364 JAMES CIR	1	ND	.0186
05	8/12/2020	11090 BIG OAK RD	1	ND	.038
06	8/12/2020	18930 HWY 120	1	ND	.0595
07	8/12/2020	18966 FERRETTI RD	1	ND	ND
08	8/12/2020	20631 LONGVIEW ST	1	ND	.0287
09	8/12/2020	17767 HWY 120	1	ND	ND
10	8/12/2020	12376 MILLS ST	1	ND	.0202
11	8/12/2020	12746 CRESTHAVEN DR	1	ND	.0481
12	8/12/2020	12984 JACKSON MILL DR	1	ND	.0303
13	8/12/2020	18743 MAIN ST	1	ND	.00641
14	8/12/2020	12858 MUELLER DR	1	ND	.00891
15	8/12/2020	14894 DARBRUSH CT	1	ND	ND
16	8/12/2020	12921 GREEN VALLEY CIR	1	ND	.00982
17	8/12/2020	20987 HILLCROFT DR	1	ND	.00878
18	8/12/2020	18983 CROCKER STATION LN	1	ND	.0191
19	8/12/2020	12795 JEFFERSON RD	1	ND	.0419
20	8/13/2020	13449 CLEMENTS RD	1	ND	.0247